

TOILET LOCATION						BIN 3
Author:	Terry Salo, CASp	Issue Date:	November 7, 2014	Sutter Health - Physical Access Compliance		
	Sutter PAC Group	Revisions:	September 11, 2019	Barrier Interpretation Notice (BIN)		
Topic No.	Topic Name	Brief Description	2019 CBC - Code Text:	2010 ADA Standards - Text:	Sutter Guidance	Additional Information
1	Distance from Sidewall	This document is a Sutter Health <u>best practice</u> and is a requirement for all Sutter Health projects. The intent of this document is to install toilets in a location that satisfies the requirements of both the 2016 CBC and the 2019 CBC as well as minimizing construction tolerance issues. It is noted that compliance with either of the CBC requirements, automatically complies with the 2010 ADA requirements.	11B-604.2 Location. The water closet shall be positioned with a wall or partition to the rear and to one side. The centerline of the water closet shall be 17 inches (432 mm) minimum to 18 inches (457 mm) maximum from the side wall or partition, except that the water closet shall be 17 inches (432 mm) minimum and 19 inches (483 mm) maximum from the side wall or partition in the ambulatory accessible toilet compartment specified in 11B-604.8.2. Water closets shall be arranged for a left-hand or right-hand approach	N/A The 2019 CBC requirements for this item match, or are more restrictive than the 2010 ADA Standards for this item.	All new water closet installations (except 'ambulatory stalls) are to be located with the centerline of the toilet set 17-1/2" from the side wall. At 'ambulatory' stalls, align the centerline of the toilet with the centerline of the ambulatory stall (required to be 35" to 37" wide per 11B-604.8.2.1)	See graphic below.

